

California Regional Water Quality Control Board, San Diego Region
9174 Sky Park Ct, Suite 100
San Diego, CA 92123

Attn: Michelle Mata

Comments on Board Order No. R9-2007-0046

Please consider the following additions/modifications to the proposed order.

- 1 Allow operation of the existing plant until the new portions of the plant are completed.
- 2 On Page 8 Section B Discharge Specifications, Paragraph 1 please insert a table of the existing limitations and a note allowing the current discharge limits to remain in effect until September 31, 2007 when the plant modifications are completed. (the Discharger will monitor all of the constituents required at the frequency specified in the Monitoring and Reporting Program)
- 3 On Page 10, Section C Facility Design and Operation Specifications, Paragraph 8, please change the Order References to the Monitoring and Reporting Program to read "R9-2007-0046"
- 4 On Page 10, Section C Facility Design and Operation Specifications, please add Paragraph 9 to read "The operation of the plant shall be reviewed at least monthly by a person certified as a Wastewater Treatment Plant Operator by the Water Resources Control Board at the level of Grade 3 or above."
- 5 On Page 10, Section D Biosolids Specifications, Paragraph 2, ...allow Biosolids to be transported and disposed in the City of San Diego treatment process under an Industrial Waste Acceptance Permit issued by the appropriate department... .

Prepared by David Thornburgh Certificate # V-2339 Phone: 530-400-0680